

SECTION 00 91 12

ADDENDUM NUMBER 3

PARTICULARS

- 1.01 DATE: JUNE 14, 2021**
- 1.02 PROJECT: THOMAS WING AT CARVER COMPLEX HVAC RENOVATION**
- 1.03 PROJECT NUMBER: DCM NO. 2021321**
- 1.04 OWNER: ALABAMA A&M UNIVERSITY**
- 1.05 ARCHITECT: NOLA | VAN PEURSEM ARCHITECTS, PC**

TO PROSPECTIVE BIDDERS

- 2.01 THIS ADDENDUM FORMS A PART OF THE CONTRACT DOCUMENTS AND MODIFIES THE BIDDING DOCUMENTS DATED MAY 5, 2021, WITH AMENDMENTS AND ADDITIONS NOTED BELOW.**
- 2.02 ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE PROPOSAL FORM. FAILURE TO DO SO MAY DISQUALIFY THE BIDDER.**
- 2.03 THIS ADDENDUM CONSISTS OF 12 PAGES.**

CHANGES TO THE PROJECT MANUAL

3.01 SECTION 01 10 00-SUMMARY:

- A. Paragraph 1.08.A: - Change paragraph to read as follows, "It is anticipated that the successful bidder will be issued a notice of award within thirty (30) days of the bid date. Substantial completion must be achieved no later than 150 calendar days after the notice to proceed is issued. Refer to Supplementary Conditions of the Contract located in Section 00 50 00 for contract requirements relating to liquidated damages and time extensions."

3.02 SECTION 01 21 00-ALLOWANCES:

- A. Paragraph 1.05.E – Change paragraph to read as follows, "Include the stipulated sum of \$45,000.00 for Alternate Add Price for occupancy sensors for occupancy override. This allowance is to be included as part of Alternate 1."

3.03 SECTION 07 81 00-SPRAY-APPLIED FIRE RESISTIVE MATERIALS:

- A. Add this section in its entirety.

CHANGES TO THE DRAWINGS

4.01 SHEET A-2 – FIRST FLOOR REFLECTED CEILING PLAN:

- A. Add note to room Mechanical 002: “Remove all existing ceiling grid, tile, and existing fireproofing. Clean surfaces thoroughly. Install new spray fireproofing on all beams, joists, and metal decking – see spec section 07 81 00. Install fire caulking at all penetrations along the perimeter and continuously along the wall and structure or metal decking joint to maintain a 2 hour separation.”

4.02 PLUMBING, FIRE PROTECTION, AND MECHANICAL:

- A. See attached Addendum#03 from Mechanical Design Services, Inc. dated June 14, 2021.

END OF ADDENDUM NUMBER 3

SECTION 07 81 00

SPRAY-APPLIED FIRE RESISTIVE MATERIALS

PART 1 GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes Sprayed-Applied Fire-Resistive Materials (SFRMs).
- B. Related Requirements:
 - 1. Division 07 Section "Intumescent Mastic Fireproofing" for mastic and intumescent fire-resistive coatings.
 - 2. Division 09 Section "Intumescent Painting" for intumescent paints that are fire retarding but not fire resistive.

1.3 PREINSTALLATION MEETINGS

- A. Preinstallation Conference: Conduct conference at Project site.
 - 1. Review products, design ratings, restrained and unrestrained conditions, densities, thicknesses, bond strengths, and other performance requirements.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Shop Drawings: Framing plans, schedules, or both, indicating the following:
 - 1. Extent of fireproofing for each construction and fire-resistance rating.
 - 2. Applicable fire-resistance design designations of a qualified testing and inspecting agency acceptable to authorities having jurisdiction.
 - 3. Minimum fireproofing thicknesses needed to achieve required fire-resistance rating of each structural component and assembly.
 - 4. Treatment of fireproofing after application.

1.5 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For Installer and testing agency.
- B. Product Certificates: For each type of fireproofing.
- C. Evaluation Reports: For fireproofing, from third party.
- D. Preconstruction Test Reports: For fireproofing.

- E. Field quality-control reports.

1.6 QUALITY ASSURANCE

- A. Installer Qualifications: A firm or individual certified, licensed, or otherwise qualified by fireproofing manufacturer as experienced and with sufficient trained staff to install manufacturer's products according to specified requirements.
- B. Mockups: Build mockups Indicate portion of Work represented by mockup on Drawings or draw mockup as separate element.
 - 1. Build mockup of as shown on Drawings.
 - 2. Approval of mockups does not constitute approval of deviations from the Contract Documents contained in mockups unless Architect specifically approves such deviations in writing.
 - 3. Subject to compliance with requirements, approved mockups may become part of the completed Work if undisturbed at time of Substantial Completion.
- C. It is recommended that industry guidelines as noted in National Fireproofing Contractors Association (NFCA) 100 – Standard Practice for the Application of Spray-Applied Fire Resistive Materials (SFRMs) be maintained on the project site.

1.7 PRECONSTRUCTION TESTING

- A. Preconstruction Testing Service: Owner will engage a qualified testing agency to perform preconstruction testing on fireproofing.
 - 1. Provide test specimens and assemblies representative of proposed materials and construction.
- B. Preconstruction Adhesion and Compatibility Testing: Test for compliance with requirements for specified performance and test methods.
 - 1. Bond Strength: Test for cohesive and adhesive strength according to ASTM E 736. Provide bond strength indicated in referenced fire-resistance design, but not less than minimum specified in Part 2.
 - 2. Density: Test for density according to ASTM E 605. Provide density indicated in referenced fire-resistance design, but not less than minimum specified in Part 2.
 - 3. Verify that manufacturer, through its own laboratory testing or field experience, attests that primers or coatings are compatible with fireproofing.
 - 4. Schedule sufficient time for testing and analyzing results to prevent delaying the Work.
 - 5. For materials failing tests, obtain applied-fireproofing manufacturer's written instructions for corrective measures including the use of specially formulated bonding agents or primers.

1.8 FIELD CONDITIONS

- A. Environmental Limitations: Do not apply fireproofing when ambient or substrate temperature is 40 deg F 4.4 deg C or lower unless temporary protection and heat are provided to maintain temperature at or above this level for 24 hours prior to, during, and for 24 hours after product application.

- B. Ventilation: Ventilate building spaces during and after application of fireproofing, providing a minimum 4 complete air exchanges per hour and according to manufacturer's written instructions until Spray-Applied Fire Resistive Materials are dried and cured. Use natural means or, if they are inadequate, forced-air circulation until fireproofing dries thoroughly.

PART 2 - PRODUCTS

2.1 MATERIALS, GENERAL

- A. Assemblies: Provide fireproofing, including auxiliary materials, according to requirements of each fire-resistance design and manufacturer's written instructions.
- B. Source Limitations: Obtain fireproofing from single source.
- C. Fire-Resistance Design: Indicated on Drawings, tested according to ASTM E 119/UL 263 by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.
 - 1. Steel members are to be considered unrestrained unless specifically noted otherwise.
- D. VOC Content: Products shall comply with VOC content limits of authorities having jurisdiction.
- E. Low-Emitting Materials: Fireproofing used within the weatherproofing system shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- F. Asbestos: Provide products containing no detectable asbestos.
- G. Products shall possess DECLARE Label
 - 1. Declaration Status "LBC Red List Free"

2.2 SPRAY-APPLIED FIRE RESISTIVE MATERIALS

- A. SFRM: Manufacturer's standard, factory-mixed, lightweight, dry formulation, complying with indicated fire-resistance design and mixed with water at Project site to form a slurry or mortar before conveyance and application or conveyed in a dry state and mixed with atomized water at place of application.
- B. Products: Subject to compliance with requirements, provide one of the following:
 - 1. Concealed/Commercial SFRMs:
 - a. ISOLATEK International: CAFCO® 300 Series (ISOLATEK® Type 300 Series), CAFCO® BLAZE-SHIELD® II (ISOLATEK® Type II) or approved equal.
 - b. Physical Properties:
 - 1) Bond Strength: Minimum 150-lbf/sq. ft. (7.18-kPa) cohesive and adhesive strength based on field testing according to ASTM E 736.

- 2) Density: Not less than 15 lb/cu. ft. (240 kg/cu. m) as specified in the approved fire-resistance design, according to ASTM E 605.
- 3) Thickness: As required for fire-resistance design indicated, measured according to requirements of fire-resistance design.
- 4) Combustion Characteristics: When tested in accordance with ASTM E 136 shall be noncombustible.
- 5) Surface-Burning Characteristics: When tested in accordance with ASTM E 84 or CAN4-S102, the material shall exhibit the following surface burning characteristics:
 - a) Flame Spread Index 10 or less
 - b) Smoke Developed 10 or less
- 6) Compressive Strength: When tested in accordance with ASTM E 761, the material shall not deform more than 10 percent when subjected to a crushing force of 1,440 psf (68.9 kPa).
- 7) Corrosion Resistance: No evidence of corrosion according to ASTM E 937.
- 8) Deflection: No cracking, spalling, or delamination according to ASTM E 759.
- 9) Effect of Impact on Bonding: No cracking, spalling, or delamination according to ASTM E 760.
- 10) Air Erosion: Maximum weight loss of 0.025 g/sq. ft. (0.270 g/sq. m) in 24 hours according to ASTM E 859.
- 11) Fungal Resistance: When tested in accordance with ASTM G21, the material shall show resistance to mold growth for a minimum period of 28

2.3 AUXILIARY MATERIALS

- A. General: Provide auxiliary materials that are compatible with fireproofing and substrates and are approved by UL or another testing and inspecting agency acceptable to authorities having jurisdiction for use in fire-resistance designs indicated.
- B. Substrate Primers: Primers approved by fireproofing manufacturer and complying with one or both of the following requirements:
 1. Fireproofing manufacturer shall be contacted for procedures on handling primed/painted steel.
 2. Primer's bond strength in required fire-resistance design complies with specified bond strength for fireproofing and with requirements in UL's "Fire Resistance Directory" or in the listings of another qualified testing agency acceptable to authorities having jurisdiction, based on a series of bond tests according to ASTM E 736.
- C. Bonding Agent: Product approved by fireproofing manufacturer and complying with requirements in UL's "Fire Resistance Directory" or in the listings of another qualified testing agency acceptable to authorities having jurisdiction.
- D. Metal Lath: Expanded metal lath fabricated from material of weight, configuration, and finish required, according to fire-resistance designs indicated and fireproofing

manufacturer's written recommendations. Include clips, lathing accessories, corner beads, and other anchorage devices required to attach lath to substrates and to receive fireproofing.

- E. Reinforcing Fabric: Glass or carbon fiber fabric of type, weight, and form required to comply with fire-resistance designs indicated; approved and provided by fireproofing manufacturer.
- F. Reinforcing Mesh: Metallic mesh reinforcement of type, weight, and form required to comply with fire-resistance design indicated; approved and provided by fireproofing manufacturer. Include pins and attachment.
- G. Sealer: If required, a transparent-drying, water-dispersible, tinted protective coating as recommended by fireproofing manufacturer.
 - 1. Product: Subject to compliance with requirements, provide CAFCO® BOND-SEAL (ISOLATEK® Type EBS) or CAFCO® BOND-SEAL Type X (ISOLATEK® Type X) by ISOLATEK International.
- H. Topcoat: If required, a topcoat suitable for application over applied fireproofing; of type recommended by fireproofing manufacturer.
 - 1. Cement-Based Topcoat: Factory-mixed, cementitious hard-coat formulation for trowel or spray application over SFRM.
 - a. Product: Subject to compliance with requirements, provide CAFCO® FENDOLITE® M-II (ISOLATEK® Type M-II), CAFCO® FENDOLITE® TG (ISOLATEK® Type TG) by ISOLATEK International.
 - 2. Water-Based Permeable Topcoat: Factory-mixed formulation for brush, roller, or spray application over applied SFRM. Provide application at a rate of [30 sq. ft./gal. (0.75 sq. m/L)] [60 sq. ft./gal. (1.5 sq. m/L)] [120 sq. ft./gal. (3 sq. m/L)].
 - a. Product: Subject to compliance with requirements, provide CAFCO® TOP-COTE (ISOLATEK® Type TOP-COTE) by ISOLATEK International.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for substrates and other conditions affecting performance of the Work and according to each fire-resistance design. Verify compliance with the following:
 - 1. Substrates are free of dirt, oil, grease, release agents, rolling compounds, mill scale, loose scale, incompatible primers, paints, and encapsulants, or other foreign substances capable of impairing bond of fireproofing with substrates under conditions of normal use or fire exposure.
 - 2. Clips, hangers, supports, sleeves and other attachments to the substrate are to be placed by others prior to the application of the fireproofing materials.
 - 3. The installation of ducts, piping, conduit or other suspended equipment shall not take place until the application of the fireproofing is complete in an area.
- B. Fire protection shall not be applied to steel floor decks prior to the completion of concrete work on that deck.

- C. The application of fireproofing to the underside of roof deck shall not commence until the roof is completely installed and tight, all penthouses are complete, all mechanical units have been placed, and construction roof traffic has ceased. When roof traffic is anticipated, as in the case of periodic maintenance, roofing pavers shall be installed as a walkway to distribute loads.
- D. Prepare written report, endorsed by Installer, listing conditions detrimental to performance of the Work.
- E. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Cover other work subject to damage from fallout or overspray of fireproofing materials during application.
- B. Clean substrates of substances that could impair bond of fireproofing.
- C. For applications visible on completion of Project, repair substrates to remove surface imperfections that could affect uniformity of texture and thickness in finished surface of fireproofing. Remove minor projections and fill voids that would telegraph through fire-resistant products after application.

3.3 APPLICATION

- A. Construct fireproofing assemblies that are identical to fire-resistance design indicated and products as specified, tested, and substantiated by test reports for thickness, primers, sealers, topcoats, finishing, and other materials and procedures affecting fireproofing work.
- B. Comply with fireproofing manufacturer's written instructions for mixing materials, application procedures, and types of equipment used to mix, convey, and apply fireproofing as applicable to particular conditions of installation and as required to achieve fire-resistance ratings indicated.
- C. Coordinate application of fireproofing with other construction to minimize need to cut or remove fireproofing.
 - 1. Do not begin applying fireproofing until clips, hangers, supports, sleeves, and other items penetrating fireproofing are in place.
 - 2. Defer installing ducts, piping, and other items that would interfere with applying fireproofing until application of fireproofing is completed.
- D. Install auxiliary materials as required, as detailed, and according to fire-resistance design and fireproofing manufacturer's written recommendations for conditions of exposure and intended use. For auxiliary materials, use attachment and anchorage devices of type recommended in writing by fireproofing manufacturer.

- E. Spray apply fireproofing to maximum extent possible. Following the spraying operation in each area, complete the coverage by trowel application or other placement method recommended in writing by fireproofing manufacturer.
- F. Extend fireproofing in full thickness over entire area of each substrate to be protected.
- G. Install body of fireproofing in a single course unless otherwise recommended in writing by fireproofing manufacturer.
- H. For applications over encapsulant materials, including lockdown (post-removal) encapsulants, apply fireproofing that differs in color from that of encapsulant over which it is applied.
- I. Where sealers are used, apply products that are tinted to differentiate them from fireproofing over which they are applied.
- J. Provide a uniform finish complying with description indicated for each type of fireproofing material and matching finish approved for required mockups.
- K. Cure fireproofing according to fireproofing manufacturer's written recommendations.
- L. Do not install enclosing or concealing construction until after fireproofing has been applied, inspected, and tested and corrections have been made to deficient applications.
- M. Finishes: Where indicated, apply fireproofing to produce the following finishes:
 - 1. Manufacturer's Standard Finishes: Finish according to manufacturer's written instructions for each finish selected.
 - 2. Spray-Textured Finish: Finish left as spray-applied with no further treatment.
 - 3. Rolled, Spray-Textured Finish: Even finish produced by rolling spray-applied finish with a damp paint roller to remove drippings and excessive roughness.
 - 4. Skip-Troweled Finish: Even leveled surface produced by troweling spray-applied finish to smooth out the texture and neaten edges.
 - 5. Skip-Troweled Finish with Corner Beads: Even, leveled surface produced by troweling spray-applied finish to smooth out the texture, eliminate surface markings, and square off edges.

3.4 FIELD QUALITY CONTROL

- A. Special Inspections: Owner will engage a qualified special inspector to perform the following special inspections:
 - 1. Test and inspect as required by Chapter 17 of the IBC.
 - 2. For reference, utilize AWCI - Inspection Procedure for Field-Applied Sprayed Fire-Resistive Materials, Technical Manual 12-A; an annotated guide.
- B. Test and inspect completed work in successive stages. Do not proceed with application of fireproofing for the next area until test results for previously completed applications of fireproofing show compliance with requirements. Tested values must

equal or exceed values as specified and as indicated and required for approved fire-resistance design.

- C. Application will be considered defective if it does not pass tests and inspections.
 - 1. Remove and replace fireproofing that does not pass tests and inspections, and retest.
 - 2. Apply additional fireproofing, per manufacturer's written instructions, where test results indicate insufficient thickness, and retest.
- D. Prepare test and inspection reports.

3.5 CLEANING, PROTECTING, AND REPAIRING

- A. Cleaning: Immediately after completing spraying operations in each containable area of project, remove material overspray and fallout from surfaces of other construction and clean exposed surfaces to remove evidence of soiling.
- B. Protect fireproofing, according to advice of manufacturer and installer, from damage resulting from construction operations or other causes, so fireproofing will be without damage or deterioration at time of Substantial Completion.
- C. As installation of other construction proceeds, inspect fireproofing and repair damaged areas and fireproofing removed due to work of other trades.
- D. Repair fireproofing damaged by other work before concealing it with other construction.
- E. Repair fireproofing by reapplying it using same method as original installation or using manufacturer's recommended trowel-applied product.

END OF SECTION

The logo for Mechanical Design Services, Inc. (mds) features the lowercase letters 'm', 'd', and 's' in a bold, sans-serif font. The 'm' and 'd' are connected. The letters are black with a blue-to-red gradient shadow underneath.

Mechanical Design Services, Inc.

100 Church Street SW, Suite 650

Huntsville, AL 35801 (256)534-5150

mds@mdseng.com

Addendum #03

Alabama A&M University Thomas Wing at Carver Complex HVAC Renovation

June 14, 2021



General

New wash down solenoids and controllers are to be provided and integrated into the respective perchloric fume hood and exhaust fan systems.

Specifications

None

Drawings

None

Equipment Submitted for Substitution Consideration:

To comply with the State Bid Law, the following equipment will be considered. No other substituted equipment or materials will be considered except those listed below. The Contractor shall note this is not an approval of the equipment listed being connected capacities, connected performances, service clearances, etc., were not all submitted or were not complete but is stating which manufacturers will be considered and approved if found to be equal to the Basis of Design equipment during the submittal phase. The Contractor must provide and compensate, at no additional cost to the Owner, Engineer, Architect and all trades (e.g. Electrical, Controls, General Works, etc.) for any modifications or additional materials, equipment, components and devices required by the substituted equipment, material, fixture, and / or device. Equipment must meet the scheduled and specified connected performance, warranty, accessories, features, components, service clearances, dimensions, etc.

Warranties are to start at substantial completion. Any required additional warranties are to be added as necessary for equipment to be under warranty during construction with specified warranties to begin on date of substantial completion.

The logo for Mechanical Design Services, Inc. (mds) features the lowercase letters 'm', 'd', and 's' in a bold, black, sans-serif font. The letters are arranged horizontally, with 'm' on the left, 'd' in the middle, and 's' on the right. A blue swoosh underline is positioned beneath the 'm' and 'd', while a red swoosh underline is positioned beneath the 'd' and 's'.

m**d****s**

Mechanical Design Services, Inc.

100 Church Street SW, Suite 650

Huntsville, AL 35801 (256)534-5150

mds@mdseng.com

PLUMBING:

- Prior approval package sent by Williams and Associates.

FIRE PROTECTION:

- No prior approval requests were submitted for consideration as specified.

MECHANICAL:

Pumps: Suction Diffusers, Triple Duty Valves, HVAC Circuit Setters, Flex Connectors

- Bell & Gossett
- Armstrong

Grilles, Registers and Diffusers:

- Titus
- Price

Wall Louvers, Penthouse Louvers, Fire Dampers, Manual Dampers and Control Dampers:

- Ruskin
- Greenheck

Fire Dampers, Control Dampers, Balancing Dampers:

- Titus
- Greenheck

Exhaust Fans and Roof Caps:

- Loren Cook
- Greenheck
- Quickdraft (perchloric fume hood exhaust fans)
- Plasticair (perchloric fume hood exhaust fans)

END OF ADDENDUM #03